



# *Mystic Air Quality Consultants, Inc.*

**1204 North Road, Groton, Connecticut 06340**

[www.mysticair.com](http://www.mysticair.com)

[maq2@aol.com](mailto:maq2@aol.com)

800 247-7746

March 13, 2024

Doug Solek  
Town of Berlin  
11 Town Farm Lane  
Berlin, CT 06037

Re: **Radon Testing –Berlin Board of Education (2/26/24 – 2/29/24)**  
238 Kensington Road; Berlin, CT

Dear Doug:

As requested, Mystic Air Quality Consultants, Inc. conducted radon testing at the location above on February 26<sup>th</sup>, 2024 – February 29<sup>th</sup>, 2024. The kits were placed in their respective locations at your facilities, then picked up and mailed to Airchek lab, where Mystic Air Quality arranged for analytical services. The testing was conducted by a Certified Radon Specialist, Christopher Muller (NRSB License #6SS0019).


**The results for radon in air are summarized below:**

<u>Location</u>	<u>Radon Test Kit #</u>	<u>Result (pCi/L)</u>
Batista Office	11719620	<0.3
Blank -1	11719641	<0.3
Brace Office	11719647	<0.3
Main Office	11719648	<0.3
Main Office (dup.)	11719649	<0.3


A concentration of 4.0 picocuries of radon per liter of air (pCi/L) is the threshold at which the US EPA recommends further testing and consideration of remediation. **All locations are safe for occupancy under current EPA standards for radon.**

Thank you for selecting Mystic Air Quality Consultants, Inc. for these services.

Sincerely,

  
Christopher J. Eident CIH, CSP, MPH  
CEO

Enclosure 1: School Radon Testing Report Form  
Enclosure 2: Laboratory Analysis Report Results & Roster



STATE OF CONNECTICUT  
DEPARTMENT OF PUBLIC HEALTH  
RADON PROGRAM  
SCHOOL RADON RE-EVALUATION REPORT FORM



July 2023

The following form must be submitted to the Connecticut Department of Public Health Radon Program within ten (10) business days of providing a final written report of radon measurement activities to school personnel.

**Do not send test results or other documents.**

Submit this signed form by email to the Radon Program at:

[DPH.RadonReports@ct.gov](mailto:DPH.RadonReports@ct.gov)

Name of School:

BERLIN BOARDS OF EDUCATION

Address:

(Street, town, zip code)

238 KENSINGTON ROAD  
BERLIN, CT 06037

Measurement Company:

MYSTIC AIR QUALITY CONSULTANTS

Please provide the following summary information:

**Dates of Testing:**

(Deployment/retrieval dates. Include confirmatory testing dates, if applicable.)

02/26/2024 To 02/29/2024

**Total # of Rooms Tested:**

3

**Total # of Rooms Requiring Re-Testing:**

0

**Total # of Rooms Where Average Results Were at or above 4.0 pCi/L:**

0

Radon measurement activities were carried out in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance* at the location described above.

CHRISTOPHER MULLER / 6550019  
Measurement Professional / NRPP (NRSB #)

Signature

3/13/2024  
Date

Ashley L. Dorsey / Director of Finance  
School Designee / Title

Signature

3/18/24  
Date



Phone: (860) 509-7300  
Telephone Device for the Deaf (860) 509-7191  
410 Capitol Avenue - MS # 12-RAD  
P.O. Box 340308, Hartford, CT 06134  
An Equal Opportunity Employer

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
11719620	2024-02-26	8:00 am	2024-02-29	9:00 am	70	BOARD OF EDUCATION	238 KENSINGTON ROAD, BERLIN, CT	BATISTA OFFICE		1	<0.3
11719641	2024-02-26	8:00 am	2024-02-29	9:00 am	70	BOARD OF EDUCATION	238 KENSINGTON ROAD, BERLIN, CT	B - 1		1	<0.3
11719647	2024-02-26	8:00 am	2024-02-29	9:00 am	70	BOARD OF EDUCATION	238 KENSINGTON ROAD, BERLIN, CT	BRACE OFFICE		1	<0.3
11719648	2024-02-26	8:00 am	2024-02-29	9:00 am	70	BOARD OF EDUCATION	238 KENSINGTON ROAD, BERLIN, CT	MAIN OFFICE		1	<0.3
11719649	2024-02-26	8:00 am	2024-02-29	9:00 am	70	BOARD OF EDUCATION	238 KENSINGTON ROAD, BERLIN, CT	MAIN OFFICE		1	<0.3

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498



238 KENSINGTON ROAD  
BETHUN, CT 06037

**Mystic Air Quality Consultants, Inc.**  
1204 North Road, Groton, Connecticut 06340 (860) 449-8903

B.O.E.

Detector ID	Sample Location	Start Time	End Time	Notes
		2/26/24	2/29/24	
		0800	0900	
✓ 11719649	MAIN OFFICE [Dup.]	↓	↓	
✓ 11719648	" "			
✓ 11719647	BRACE OFFICE			
✓ 11719620	BATISTA OFFICE			
11719641	BLANK	↓	↓	
Dup.				
Dup.				